



Mark Avery <madplanboard@gmail.com>

Atlantic Broadband.

1 message

Tom Perley <tperley@madburyfire.org>
To: Mark Avery <madplanboard@gmail.com>
Cc: Eric Fiegenbaum <adminmadbury@comcast.net>

Tue, Aug 17, 2021 at 4:28 AM

Mark,

The Madbury Fire Department has no issue with this subdivision.

The only requirement that I would like to see is that all buildings and gates placed as part of this subdivision shall be accessible to the Fire Department using either a Knox Box or Knox Padlock, using the Madbury Fire Department Keyway, provided at the owners expense. I am assuming that I will be seeing building plans at a later time.

Tom Perley
Fire Chief/EMD
Town of Madbury
334 Knox Marsh Road
Madbury, NH 03823
Office - (603) 742-1164